



BVVS

BILURU GURUBASAVA MAHASWAMIJI INSTITUTE OF TECHNOLOGY

(Estd:2012)

(Recognized by Government of Karnataka & AICTE New Delhi and Affiliated to Visvesvaraya Technological University, Belgaum)

Mantur Road, Bagalkot- 587313, Karnataka State.

08350-280404, 281404

email: bvvsbgmitm@gmail.com

website: www.bgmitm.ac.in

DEPARTMENT OF CIVIL ENGINEERING

Ref. No. BGMIT/BDM/105 /2024-25

Date: 07/02 /2024

WATER QUALITY ANALYSIS REPORT

Name of the Agency/ Contractor: Cambridge Higher Primary School


Name of the work: Water Quality Analysis

Sample receive on: 07/02 /2024

Date of Testing: 07/02 /2024

Parameter	Turbidity (NTU)	Total Hardness (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Chloride (mg/L)	Alkalinity as CaCO ₃ (mg/L)	Acidity (mg/L)	pH	Colour	Odour	TDS (ppm)	Remark
Acceptable	5	300	75	30	250	200	--	6.5 - 8.5	5	--	500	--
Cause for rejection(>)	10	600	200	100	1000	600	--	No. relaxation	--	--	2000	--
Water Sample 1	07	48	08	07	30	72	10	7.05	Colour less	Agreeable	32	P

Remarks: NP-Not Portable, P-Portable for Drinking, ppm-parts per million, NTU- Nephelometric Turbidity unit


Faculty In charge


Co-ordinator